



Product Service

# CERTIFICATE

No. Z1 041210 0048 Rev. 00

**Holder of Certificate:** **Möhlenhoff GmbH**  
 Museumstr. 54 a  
 38229 Salzgitter  
 GERMANY

**Production Facility(ies):** 041210

**Certification Mark:**



**Product:** **Heating controller**  
**Model(s):** **Motoric Valve Drives**  
**Type:** **MPR, MPO, M3P, MPV**

**Parameters:**

M3P	xyz	3-point & fixed cable
M3P	xyz	3-point & socket
MPR	xyz	proportional & socket
MPV	xyz	proportional & socket + with valve path sensing
MPO	xyz	proportional & socket with 0-10 V control voltage with valve path sensing

x represents the version and can have the values 2, 4 or 5.

- 2: 230 V
- 4: 24 V
- 5: 110/230 V

y represents the voltage version and can have the values 6 or 7.

- 6: AC/DC
- 7: AC

z represents further non safety relevant model variants.

**Tested according to:** EN 60730-1:2011  
 EN 60730-2-14:1997/A2:2008

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 028-713117764-000  
**Valid until:** 2023-08-08

**Date,** 2018-08-20

*Abba*  
 ( Abdul Sabbagh )