



**KONFORMITÄTSERKLÄRUNG  
DECLARATION OF CONFORMITY  
DECLARATION DE CONFORMITE**

**Gemäß / In Accordance with / Conforme à:**

**Titel** **Druckgeräte Richtlinie**  
Title Presssure Equipment Directive  
Titre Directive Equipments sous Pression

**Produkt / Product / Produit:** **V5050A /B PN16 Ventil (DN100-DN150)**  
**V5050A/B PN16 Valve**  
**V5050A/B PN25/40 Ventil (DN15-DN100)**  
**V5050A/B PN25 /40Valve**

**Anbieter / Supplier / Fournisseur:** **HONEYWELL**  
**Anschrift / Address / Adresse:** **Hardhofweg, D-74821 Mosbach/Germany**

**Kennzeichen / Mark / Marquage** **CE 0035**

**Dokument / Document / Document** **Titel / Title / Titre** **Ausgabe / Edition / Edition**

**DIN IEC 534** **Industrial-process control valves; Flow capacity; Inherent flow**  
**Part 2-4** **Characteristics and rangeability** (Nov. 1990)

**ISO 7005** **Metallic flanges**

**DIN 2533** **Cast Iron EN-GJL-250 (GG25) flanges; nominal pressure 16 bar (DN100-DN150)**  
**DIN 2544 / 2545** **Cast steel GP240H (GS-C25) flanges; nominal pressure 25/40 bar (DN15-DN100)**

**PED** **With this we confirm that up to DN50 there is no CE-Marking of these products. The sizes DN65 to DN150 fall under category I or higher and therefore can be applied with CE- Marking**

**EG Richtlinien & harmonisierte Normen, EG -Normentwürfe**

EC guidlines & harmonized norms, EC-project norms  
Directives CE & normes harmonisées, projet de normes- CE

**Die Überwachung erfolgt durch: TÜV Anlagentechnik GmbH**  
The monitoring is performed by: **Am Grauen Stein**  
La surveillance est effectuee par: **51105 Köln**

Jürgen Arold - Engineering Leader HVAC Field Devices

(Name, Funktion/ Name, Function/ Nom, fonction)

(Unterschrift/Signature/Signature)

Mosbach, 04.07.2003